



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17011-73-371
State Number
23700

EQUIPMENT INSPECTED

State Number: 23700	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 1	Installed: 06/22/2006	Rope Size: 0
Volts: 480	Complied: 06/22/2006	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	KOURY BUISNESS CENTERMARTHA,SPENCER,LOVE	
803 HAGGARD AVENUE	401 N O'KELLY AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
5.1.21.1	Put the in car alarm bell in working order.
8.6.4.13.1[[]]	Properly maintain door restrictors, where required.
2.2.5.1	Put the pit lights in proper working order.
8.6.1.4.1[a]	Properly document maintenance records
8.11.3.2.1	Provide the annual relief valve and system pressure test.
8.6	Repair certificate frame
8.6	Place fire operation light inside car in proper working order
8.6	Make second floor hoistway door self closing

Items must be corrected by: 03/11/2017

Elevator Name: MARTHA-SPENCER-LOVE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: Rick

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244