



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17011-73-3765
State Number
18186

EQUIPMENT INSPECTED

State Number: 18186	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 3	Installed: 12/16/1999	Rope Size:
Volts: 480	Complied: 12/16/1999	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	CAROL GROTNES BELK LIBRARY	
803 HAGGARD AVENUE	308 N O'KELLEY AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.(location needs to be added
2.14.4.2.1	Put the car door gate switch in proper working order.
8.11.3.2.1	Provide the annual relief valve and system pressure test.

Items must be corrected by: 03/11/2017

Elevator Name: Belk library

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rick

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244