



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17011-73-4835
State Number
16582

EQUIPMENT INSPECTED

State Number: 16582	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/10/1996	Rope Size:
Volts: 208	Complied: 12/10/1996	Entrances: 2
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIV / MCEWN KITCHEN	
803 HAGGARD AVENUE	131 N WILLIAMSON AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/11/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
8.6	Replace pickup rollers on bottom hoistway door
8.6	Provide Fire exstinguisher in elevator equipment room
8.6	Machine room not to be used for storage
8.6	Clean elevator pit
8.6	Update maintenance records
8.6	Perform annual pressure test
8.6	Put cab lights in proper working order

Items must be corrected by: 03/11/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Rick

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244