



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17013-73-2045**  
State Number  
**28678**

### EQUIPMENT INSPECTED

|                            |                         |                        |
|----------------------------|-------------------------|------------------------|
| State Number: <b>28678</b> | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2100             | Manuf: SCHINDLER        | Speed: 100             |
| Landings: 2                | Installed: 01/28/2013   | Rope Size:             |
| Volts: 208                 | Complied: 01/28/2013    | Entrances: 2           |
| OWNER                      | OCCUPANT                |                        |
| ELON UNIVERSITY            | NUMEN LUMEN PAVILION    |                        |
| 2060 CAMPUS BOX            | 301 E HAGGARD AVENUE    |                        |
| ELON, NC, 27244            | ELON, NC, 27244         |                        |

### INSPECTION INFORMATION

|                               |                            |                                 |                         |                    |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date<br>01/13/2017 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>73 - James | County<br>ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

### VIOLATIONS

|            |   |
|------------|---|
| 8.11.3.2.1 | Provide the annual relief valve and system pressure test. |
| 8.6        | Machine room not to be used for storage                   |

Items must be corrected by: 03/13/2017

Elevator Name: NUMEN LUMEN PAVILION

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Lloyd

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
2060 CAMPUS BOX  
ELON, NC, 27244