



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17013-73-4665**  
State Number  
**25133**

EQUIPMENT INSPECTED

State Number: <b>25133</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 110
Landings: 3	Installed: 08/22/2007	Rope Size: 0
Volts: 208	Complied: 08/22/2007	Entrances: 2
OWNER	OCCUPANT	
ACADEMIC VILLAGE - GRAY (POLI-SCI)	ELON UNIVERSITY ALAMANCE BLDG	
304 EAST LEBANON AVENUE	107 E HAGGARD AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
2.14.7.1.3	Put the in car emergency light in working order.
8.6	Patch all holes in elevator hoistway

Items must be corrected by: 03/13/2017

Elevator Name: ALAMANCE BDLG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Lloyd

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ACADEMIC VILLAGE - GRAY (POLI-SCI)  
304 EAST LEBANON AVENUE  
ELON, NC, 27244