



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17018-73-1912
State Number
30448

EQUIPMENT INSPECTED

State Number: 30448	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 150
Landings: 3	Installed: 09/14/2016	Rope Size:
Volts: 460	Complied:	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIVERSITY COMMUNICATIONS/PAVILION	
CAMPUS BPX 84823	129 N WILLIAMSON AVENUE	
ELON, NC, 27244	BURLINGTON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/18/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.13.1[] Properly maintain door restrictors, where required.

Items must be corrected by: 03/18/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
CAMPUS BPX 84823
ELON, NC, 27244