



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17018-73-5092**  
State Number  
**18484**

#### EQUIPMENT INSPECTED

State Number: <b>18484</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 09/17/1999	Rope Size:
Volts: 200	Complied: 09/20/1999	Entrances: 1
OWNER	OCCUPANT	
BLAKEY HALL	BLAKEY HALL	
501 MANNING AVE	501 MANNING AVE	
ELON COLLEGE, NC, 27244	ELON COLLEGE, NC, 27244	

#### INSPECTION INFORMATION

Inspection Date 01/18/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6	Put fireman phase 2 in proper working order
8.6	Replace burned out lights in elevator cab

Items must be corrected by: 03/18/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Linda Vaughn

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLAKEY HALL  
501 MANNING AVE  
ELON COLLEGE, NC, 27244