



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17023-54-5576
State Number
1592

EQUIPMENT INSPECTED

State Number: 1592	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 01/18/1952	Rope Size: 1/2
Volts: 208	Complied: 01/18/1952	Entrances: 1
OWNER	OCCUPANT	
LANDMARK PROPERTY MGMT	CASHIE APARTMENTS FOR THE ELDERLY	
FOR CASHIE APTS	401 STERLINGWORTH DR	
WINSTON SALEM, NC, 27101	WINDSOR, NC, 27983	

INSPECTION INFORMATION

Inspection Date 01/23/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

8.6.4.7.4	Remove the water from the pit floor.
2.14.7.1.3	Put the in car emergency light in working order.
8.6.1.4.1[a]	Properly document maintenance records
8.11.1.6	Provide the appropriate test tag.
8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 03/22/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ASHLEY HORROCKS 252 794 2974

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANDMARK PROPERTY MGMT
FOR CASHIE APTS
WINSTON SALEM, NC, 27101