



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17023-73-1476
State Number
15316

EQUIPMENT INSPECTED

State Number: 15316	Type of Unit: Passenger	Floor to Floor: 2 to 4
Capacity: 4500	Manuf: KONE	Speed: 125
Landings: 3	Installed: 04/14/1994	Rope Size:
Volts: 480	Complied: 05/18/1995	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE REGIONAL MEDICAL CTR	ALAMANCE REGIONAL MEDICAL CTR	
PO BOX 202	1230 HUFFMAN MILL RD	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 01/23/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.13.1[[]]	Properly maintain door restrictors, where required.
8.11.3.2.1	Provide the annual relief valve and system pressure test.
8.6	Clean elevator pit

Items must be corrected by: 03/23/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Curtis

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE REGIONAL MEDICAL CTR
PO BOX 202
BURLINGTON, NC, 27216