



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17032-16-1480
State Number
22271

EQUIPMENT INSPECTED

State Number: 22271	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 50
Landings: 3	Installed: 12/17/2009	Rope Size: 0
Volts: 240	Complied:	Entrances: 1
OWNER	OCCUPANT	
MR MARK GRAY	WASHINGTON DOWNTOWN OFB	
108 N ELM STREET	158 E MAIN STREET	
GREENSBORO, NC, 27401	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 02/01/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 03/30/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jerry Gray

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MR MARK GRAY
108 N ELM STREET
GREENSBORO, NC, 27401