



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17044-66-377
State Number
16288

EQUIPMENT INSPECTED

State Number: 16288	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 150
Landings: 3	Installed: 02/13/1996	Rope Size: 0
Volts: 208	Complied: 02/13/1996	Entrances: 2
OWNER	OCCUPANT	
ALEXANDER COUNT SCHOOLS	TAYLORSVILLE ELEMENTARY SCHOOL	
700 LILEDOWN ROAD	100 7TH STREET S.W.	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.
8.6.4.9 Clean the elevator car top.
2.14.7.1.3 Put the in car emergency light in working order. AND ALARM BELL IN ORDER THESE TESTS SHOULD BE DONE
8.11.3.2.1 Perform the annual relief valve test
NOTE MAINTAINCE LOG BOOK SHOULD BE IN MECHROOM
NOTE MISSING / BROKEN HOISTWAY DOOR ROLLERS

Items must be corrected by: 04/01/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: ALEXANDER CO SCHOOLS828-632-7063

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALEXANDER COUNT SCHOOLS
700 LILEDOWN ROAD
TAYLORSVILLE, NC, 28681