



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17045-66-3359
State Number
12864

EQUIPMENT INSPECTED

State Number: 12864	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: ASK	Speed: 100
Landings: 2	Installed: 08/25/1988	Rope Size: 0
Volts: 480	Complied: 09/07/1988	Entrances: 1
OWNER	OCCUPANT	
ALEXANDER COUNTY SCHOOLS	EAST ALEXANDER MIDDLE	
700 LILEDOWN ROAD	1285 WHITE PLAINS ROAD	
TAYLORSVILLE, NC, 28681	HIDDENITE, NC, 28636	

INSPECTION INFORMATION

Inspection Date 02/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

2.14.7.1.4	Put the car top light in working order.
8.6.4.7.1	Clean the elevator pit.
8.6.4.9	Clean the elevator car top.
8.11.3.2.1	Perform the annual relief valve test and place tag on controler
NOTE	PUSH BUTTON LIGHTS NEED REPLACED PI LIGHTS ARE ALSO NOT WORKING

Items must be corrected by: 04/01/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ALEXANDER CO.SCHS. 828-632-7063

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALEXANDER COUNTY SCHOOLS
700 LILEDOWN ROAD
TAYLORSVILLE, NC, 28681