



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17045-66-4412
State Number
4369

EQUIPMENT INSPECTED

State Number: 4369	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: PARK	Speed: 60
Landings: 2	Installed: 07/13/1960	Rope Size: 0
Volts: 550	Complied: 07/13/1960	Entrances: 1
OWNER	OCCUPANT	
SHURETAPE TECHNOLOGIES	STONE POINT PLANT	
DRAWER 2228	8510 NC HWY 90 EAST	
HICKORY, NC, 28603	STONY POINT, NC, 28678	

INSPECTION INFORMATION

Inspection Date 02/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

8.6.4.8.1	Clean the elevator machine room.
8.6.4.7.1	Clean the elevator pit.
2.11.10.2	Provide adequate lighting at all landings.FIX /REPLACE MECHROOM LIGHTS

Items must be corrected by: 04/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: gmoore@shurtape.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SHURETAPE TECHNOLOGIES
DRAWER 2228
HICKORY, NC, 28603