



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17051-73-071
State Number
19496

EQUIPMENT INSPECTED

State Number: 19496	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/06/2000	Rope Size:
Volts: 208	Complied: 12/06/2000	Entrances: 1
OWNER	OCCUPANT	
MILT PETTY	ALAMANCE IND. PARK	
PO BOX 850	1225 HUFFMAN MILL RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/20/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1	Put the car lights in proper working order.
8.6.1.4.1[a]	Properly document maintenance records
8.6	Provide current class abc fire extinguisher in machine room
8.6	Machine room not to be used for storage

Items must be corrected by: 03/22/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Steve Gentry

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MILT PETTY
PO BOX 850
BURLINGTON, NC, 27215