



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17051-73-2679**  
State Number  
**23316**

#### EQUIPMENT INSPECTED

State Number: <b>23316</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 06/23/2005	Rope Size: .
Volts: 208	Complied: 06/23/2005	Entrances: 1
OWNER	OCCUPANT	
AKHLAGHI OFFICE BLDG	AKHLAGHI OFFICE BLDG	
2961 CROUSE LN	2961 CROUSE LN	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

#### INSPECTION INFORMATION

Inspection Date 02/20/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

2.7.3.4.1(b)	Provide a self closing, self locking machine room door.
8.6.4.13.1[1]	Properly maintain door restrictors, where required.
2.14.7.1	Put the car lights in proper working order.
8.6	Machine room not to be used for storage

Items must be corrected by: 03/22/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: [ainm2961@gmail.com](mailto:ainm2961@gmail.com)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AKHLAGHI OFFICE BLDG  
2961 CROUSE LN  
BURLINGTON, NC, 27215