



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17067-16-2778**  
State Number  
**9865**

EQUIPMENT INSPECTED

State Number: <b>9865</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SOUTHERN	Speed: 125
Landings: 4	Installed: 08/17/1981	Rope Size: 0
Volts: 208	Complied: 05/12/2003	Entrances: 1
OWNER	OCCUPANT	
WASHINGTON HOUSING AUTHORITY	EAST HAVEN	
PO BOX 1046	407 E. THIRD STREET	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 03/08/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 05/07/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WASHINGTON HOUSING AUTHORITY  
PO BOX 1046  
WASHINGTON, NC, 27889