



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17067-66-2724
State Number
5796

EQUIPMENT INSPECTED

State Number: 5796	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: REMCO	Speed: 30
Landings: 2	Installed: 05/23/1967	Rope Size: 0
Volts: 220	Complied: 08/24/1967	Entrances: 2
OWNER	OCCUPANT	
ADAMS FUNERAL HOME LLC	ADAMS FUNERAL HOME	
P.O. BOX 937	307 MAIN AVENUE DRIVE	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 03/08/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: adams funeral home 828-632-2291

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ADAMS FUNERAL HOME LLC
P.O. BOX 937
TAYLORSVILLE, NC, 28681