



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17067-73-3583**  
State Number  
**11065**

EQUIPMENT INSPECTED

State Number: <b>11065</b>	Type of Unit: Passenger	Floor to Floor: G to 1
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 01/15/1985	Rope Size:
Volts: 480	Complied: 01/15/1985	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE CO	HUMAN SERVICES FACILITIES	
124 W ELM ST	319 N GRAHAM / HOPEDALE RD	
GRAHAM, NC, 27253	BURLINGTON, NC, 27217	

INSPECTION INFORMATION

Inspection Date 03/08/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.11.3.2.1	Provide the annual relief valve and system pressure test.
8.6	Provide " in case of fire" sign on each landing
8.6	Machine room door must be self closing self locking
8.6	remove oil from pit floor

Items must be corrected by: 04/07/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO  
124 W ELM ST  
GRAHAM, NC, 27253