



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17068-73-0143
State Number
29663

EQUIPMENT INSPECTED

State Number: 29663	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 5000	Manuf: TKE	Speed: 135
Landings: 3	Installed: 03/23/2015	Rope Size:
Volts: 208	Complied: 03/23/2015	Entrances: 1
OWNER	OCCUPANT	
COMPASS POINTE CENTER LLC	COMPASS POINTE STORAGE CAR 2	
P O BOX 10	HWY 119	
WHITSETT, NC, 27377	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 03/09/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
5.1.21.1	Put the in car alarm bell in working order.
8.6	Place car gate switch in working order

Items must be corrected by: 04/08/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: steve@compasspointeselfstorage.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMPASS POINTE CENTER LLC
P O BOX 10
WHITSETT, NC, 27377