



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17072-66-2925**  
State Number  
**21159**

EQUIPMENT INSPECTED

State Number: <b>21159</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 11/17/2003	Rope Size: 0
Volts: 480	Complied: 11/17/2003	Entrances: 1
OWNER N.C. DEPARTMENT OF CORRECTIONS 831 WEST MORGAN STREET RALEIGH, NC, 27603		OCCUPANT ALEXANDER CORRECTIONAL 633 OLD LANDFILL RD TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date 03/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 66 - Pacitti	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order.or intercom to control room
8.6.4.9	Clean the elevator car top.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 04/12/2017

Elevator Name: # J

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: [allen.huffman@ncdps.gov](mailto:allen.huffman@ncdps.gov)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. DEPARTMENT OF CORRECTIONS  
831 WEST MORGAN STREET  
RALEIGH, NC, 27603