



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17072-72-4627
State Number
5938

EQUIPMENT INSPECTED

State Number: 5938	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 2000	Manuf: SCHINDLER	Speed: 300
Landings: 6	Installed: 03/27/1968	Rope Size: 1/2
Volts: 208	Complied: 04/08/1968	Entrances: 1
OWNER	OCCUPANT	
FIRST EMPIRE TELEX	FIRST RALEIGH TELEX BLDG	
C/O EMPIRE PROPERTIES	234 FAYETTEVILLE ST	
RALEIGH, NC, 27601	RALEIGH, NC, 27601	

INSPECTION INFORMATION

Inspection Date 03/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 72 - Mccloud	County WAKE	92 D
-------------------------------	----------------------------	---------------------------------	---------------------------	----------------	------

VIOLATIONS

- 8.6.4.16 The elevator shall be maintained to provide a stopping accuracy at the landings during normal operation. [fix leveling problem]
- 8.6.8.9 Signs. Firefighter poeration signs shall be provided. Damaged or missing signs shall be replaced.
- 8.11.2.2.2 Perform the annual no load safety test

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: julie wood Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST EMPIRE TELEX
C/O EMPIRE PROPERTIES
RALEIGH, NC, 27601