



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17073-73-0365
State Number
30199

EQUIPMENT INSPECTED

State Number: 30199	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 3500	Manuf: OTIS	Speed: 350
Landings: 6	Installed: 04/28/2016	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
DRURY DEVELOPMENT CORP	DRURY INN & SUITES BURLINGTON CAR 1	
721 EMERSON RD STE 200	1767 GLIDEWELL DRIVE	
ST LOUIS, MO, 63141	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6	Perform category 1 testing
8.6	Clean the elevator pit

Items must be corrected by: 04/13/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: michael.mahoney@druryhotels.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DRURY DEVELOPMENT CORP
721 EMERSON RD STE 200
ST LOUIS, MO, 63141