



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17073-73-053**  
State Number  
**25205**

#### EQUIPMENT INSPECTED

State Number: <b>25205</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 09/25/2007	Rope Size:
Volts: 208	Complied: 09/25/2007	Entrances: 1
OWNER	OCCUPANT	
NCR MANAGEMENT	FIVE STAR BUILDING	
PO BOX 96	105 E CENTER STREET	
ELON, NC, 27244	MEBANE, NC, 27302	

#### INSPECTION INFORMATION

Inspection Date 03/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 04/13/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: [info@ncrmanagement.com](mailto:info@ncrmanagement.com)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NCR MANAGEMENT  
PO BOX 96  
ELON, NC, 27244