



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17073-73-3733**  
State Number  
**27508**

#### EQUIPMENT INSPECTED

State Number: <b>27508</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: KONE	Speed: 150
Landings: 3	Installed: 02/27/2012	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
RIVERMILL VILLAGE LLC	SAXAPAHAW UPPER MILL	
PO BOX 128	1616 JORDAN DRIVE	
SAXAPAHAW, NC, 27340	SAXAPAHAW, NC, 27340	

#### INSPECTION INFORMATION

Inspection Date 03/14/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

#### VIOLATIONS

8.6	Perform category 5 testing
8.6	Tighten handrails inside elevator cab

Items must be corrected by: 04/13/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: [ted@rampartmanagement.com](mailto:ted@rampartmanagement.com)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RIVERMILL VILLAGE LLC  
PO BOX 128  
SAXAPAHAW, NC, 27340