



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17075-73-4120
State Number
811

EQUIPMENT INSPECTED

State Number: 811	Type of Unit: Freight	Floor to Floor: B to 2
Capacity: 3000	Manuf: MONARCH	Speed: 75
Landings: 3	Installed: 04/18/1947	Rope Size: 1/2
Volts: 480	Complied: 04/18/1947	Entrances: 1
OWNER	OCCUPANT	
PICKETT HOSIERY	PICKETT HOSIERY	
PO BOX 877	741 EAST WEBB STREET	
BURLINGTON, NC, 27216	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7.4	Take steps to eliminate the accumulation of water on the pit floor and remove same.
8.6.1.4.1[a]	Properly document maintenance records
8.6	Provide proper test tag for category 5 testing

Items must be corrected by: 04/15/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lon

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PICKETT HOSIERY
PO BOX 877
BURLINGTON, NC, 27216