



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17075-73-5318
State Number
27172

EQUIPMENT INSPECTED

State Number: 27172	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 150
Landings: 3	Installed: 09/23/2009	Rope Size:
Volts: 460	Complied: 09/23/2009	Entrances: 1

OWNER

HOSPICE & PALLIATIVE CARE CENTER
918 CHAPEL HILL ROAD
BURLINGTON, NC, 27215

OCCUPANT

HOSPICE & PALLIATIVE CARE CENTER
918 CHAPEL HILL ROAD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 03/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
- 8.6.1.4.1[a] Properly document maintenance records

Items must be corrected by: 04/15/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: sterrell@hospiceac.org

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HOSPICE & PALLIATIVE CARE CENTER
918 CHAPEL HILL ROAD
BURLINGTON, NC, 27215