



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17076-73-4085
State Number
2863

EQUIPMENT INSPECTED

State Number: 2863	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: MONARCH	Speed: 50
Landings: 2	Installed: 09/27/1956	Rope Size:
Volts: 220	Complied: 09/27/1956	Entrances: 1
OWNER	OCCUPANT	
SOUTHLAND ELECTRIC	SOUTHLAND ELECTRIC	
123 N MAIN ST	123 N MAIN ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/17/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Take steps to give machine room proper fire rating

Items must be corrected by: 04/16/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: scclapp@southlandelectrical.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTHLAND ELECTRIC
123 N MAIN ST
BURLINGTON, NC, 27215