



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17079-73-3264
State Number
10162

EQUIPMENT INSPECTED

State Number: 10162	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: SOUTHERN	Speed: 75
Landings: 2	Installed: 12/08/1981	Rope Size:
Volts: 440	Complied: 12/08/1981	Entrances: 1
OWNER	OCCUPANT	
ED ALEXANDER FABRICS INC	ED ALEXANDER FABRICS INC	
ST RD 1184/INDUSTRY DR.	ST RD 1184/INDUSTRY DR.	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/20/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6 Clean the elevator pit

Items must be corrected by: 04/19/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: mandy.bundren@mccombind.com

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ED ALEXANDER FABRICS INC
ST RD 1184/INDUSTRY DR.
BURLINGTON, NC, 27215