



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17083-73-0567**  
State Number  
**28810**

EQUIPMENT INSPECTED

State Number: <b>28810</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 07/24/2013	Rope Size:
Volts: 460	Complied: 07/24/2013	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON GLOBAL RESIDENCE HALLS BLDG 4	
CAMPUS BOX 2060	103 PHOENIX DRIVE	
ELON, NC, 27244	EKON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 03/24/2017	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 73 - James	County ALAMANCE
-------------------------------	-------------------------------	-----------------------------------	-------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jeremy Lloyd

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
CAMPUS BOX 2060  
ELON, NC, 27244