



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17094-73-1347**  
State Number  
**23635**

EQUIPMENT INSPECTED

State Number: <b>23635</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 102
Landings: 2	Installed: 03/23/2006	Rope Size: 0
Volts: 280	Complied: 03/23/2006	Entrances: 1
OWNER	OCCUPANT	
KINNET MEMORIAL BAPTIST CHURCH	KINNET MEMORIAL BAPTIST CHURCH	
1106 EAST MOREHEAD STREET	1106 EAST MOREHEAD STREET	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 04/04/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

- 8.6 Place cedes edge in proper working order
- 8.6 Provide class abc fire exstinguisher with current inspection in machine room

Items must be corrected by: 05/04/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: [kinnetmemorial@att.net](mailto:kinnetmemorial@att.net)

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KINNET MEMORIAL BAPTIST CHURCH  
1106 EAST MOREHEAD STREET  
BURLINGTON, NC, 27215