N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17097-73-4978
State Number
H1854

EQUIPMENT INSPECTED

State Number: **H1854**
Capacity: 750
Landings: 1
Volts: 220

Type of Unit: Hand Lift
Manuf: ACCESS
Installed: 05/17/2007
Complied: 05/17/2007

Floor to Floor: 1 to 2
Speed: 10
Rope Size: 0
Entrances: 2

OWNER
REFUGE TEMPLE CHURCH
152 N MAIN STREET
BURLINGTON, NC, 27217

OCCUPANT
REFUGE TEMPLE CHURCH
152 N MAIN STREET
BURLINGTON, NC, 27217

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/07/2017	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6	Provide manual lowering device
8.6	Make bottom door self closing
8.6	Make top door self closing

Items must be corrected by: 06/06/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: spencerb83@yahoo.com

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
REFUGE TEMPLE CHURCH
152 N MAIN STREET
BURLINGTON, NC, 27217