N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17100-48-0647
State Number
21546

EQUIPMENT INSPECTED

State Number: **21546**
Capacity: 2000
Landings: 3
Volts: 240

Type of Unit: Passenger
Manuf: CANTON
Installed: 07/02/2003
Complied: 07/11/2003

Floor to Floor: 1 to 3
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461

OCCUPANT
SOUTHPORT CONDOS BLDG.#3
610 W. BROWN STREET
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/10/2017	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA. [2ND YR]

Items must be corrected by: 05/10/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461