NCDOL NC Dopartment of Labor

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 17109-48-1388 State Number 23583

EQUIPMENT INSPECTED					
State Number: 23583 Capacity: 3000 Landings: 4 Volts: 208	Manuf: THYSS Installed: 01/10	Type of Unit: Passenger Manuf: THYSSEN KRUPP Installed: 01/10/2006 Complied: 01/10/2006		Floor to Floor: 1 to 4 Speed: 125 Rope Size: . Entrances: 1	
OWNER CAM P.O. BOX 8126 OCEAN ISLE BEACH,	OCCUPANT ISLANDER RESORT - BLDG. #33 157 VIA OLD SOUND BLVD C, 28469 OCEAN ISLE BEACH, NC, 28469				
	I	NSPECTION INFORMATION			
Inspection Date 04/19/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK	10
		VIOLATIONS			
2.27.1.1.1 n/a 6.1.6	Place the in-car Emergency Phone in w Place car button lights in proper workin Provide missing caution signs. [Fls. 1,2	ng order.			

To make changes to the invoice mailing address please call: 919-733-0372

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into

THIS IS NOT AN INVOICE

complainace with current codes.

Items must be corrected by: 05/19/2017

Violations pointed out to: UNAVAILABLE

An invoice will be mailed to:

P.O. BOX 8126

OCEAN ISLE BEACH, NC, 28469

Inspector ___