



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17116-48-2062
State Number
21610

EQUIPMENT INSPECTED

State Number: 21610	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 05/13/2003	Rope Size: 0
Volts: 208	Complied: 05/13/2003	Entrances: 1
OWNER	OCCUPANT	
CAM	ISLANDER RESORT - BLDG. #27	
P.O. BOX 8126	2 JAN STREET	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 04/26/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order. [2ND YR]

Items must be corrected by: 05/26/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469