

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 17117-65-3651 State Number 6681

	EQUIP	MENT INSPECTED		
State Number: 6681 Capacity: 2500 Landings: 4 Volts: 480	Type of Unit: Freight Manuf: OTIS Installed: 06/30/1970 Complied: 07/22/1970)	Floor to Floor: 1 to 4 Speed: 25 Rope Size: 1/2 Entrances: 2	
OWNER SUGAR MTN. RESORT IN P.O. BOX 369 BANNER ELK, NC, 28604	TC	1009 SUGAR MTN. DI	OCCUPANT SUGAR MTN. SKI LODGE 1009 SUGAR MTN. DRIVE BANNER ELK, NC, 28604	
	INSPEC	ΓΙΟΝ INFORMATION		
Inspection Date 04/27/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY 6
		VIOLATIONS		
on the rope for Provide the mis 1, 3, 5 hydraulic	am machines located below or beside the hois other type of fastenings every 1 year sing metal tag in the machine room with all pc elevators) ual no load safety test and provide proper tag.	pertinent information of the test pe		
Items must be corrected b	y: 07/26/2017			
Notify the Elevator Bureau in complainace with current code	writing on Corrected Violations Form when tes.	he following corrections have be	en made in order to bring you	equipment into
Violations pointed out to: Kei	th Lane 828-387-6814		Inspector	
THIS IS NOT AN INVOICE	To make changes to the invoice mailing a An invoice will be mailed to:			