



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17117-65-4013
State Number
11158

EQUIPMENT INSPECTED

State Number: 11158	Type of Unit: Passenger	Floor to Floor: L to 10
Capacity: 2500	Manuf: THYSEN KRUPP	Speed: 350
Landings: 11	Installed: 09/10/1985	Rope Size: 5/8
Volts: 208	Complied: 03/24/2006	Entrances: 1

OWNER
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

OCCUPANT
SUGAR TOP RESORT
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 04/27/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 06/26/2017

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sam 828-898-5226

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604