N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**17117-65-5546**
State Number
**10465**

## EQUIPMENT INSPECTED

State Number: **10465**
Capacity: 2500
Landings: 11
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 10/07/1983
Complied: 10/04/2006

Floor to Floor: L to 11
Speed: 350
Rope Size: 1/2
Entrances: 1

OWNER
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

OCCUPANT
SUGAR TOP RESORT
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County |
|---|---|---|---|---|
| 04/27/2017 | Routine | Re-issued | 65 - Kelley | AVERY |

6

## VIOLATIONS

8.11.2.3 Perform a 5 year full load safety test
8.6.4.9 Clean the elevator car top of oil and debris.
8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machine rooms and machinery spaces.
NEC Provide pit light protection (cage or jar)

Items must be corrected by: 05/27/2017

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Sam 828-898-5226

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604