N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17123-48-1571
State Number
24237

EQUIPMENT INSPECTED

State Number: **24237**
Capacity: 2500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 01/30/2007
Complied: 01/30/2007

Floor to Floor: 1 to 3
Speed: 125
Rope Size: 0
Entrances: 1

OWNER
CHAD MORRIS
371 NORTH BILHEN STREET
TROY, NC, 27371

OCCUPANT
YAUPON DUNES
700 OCEAN DRIVE
OAK ISLAND, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/03/2017	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.13.1 (c Place the door re-opening device in proper working order. [FALSE FIRES CAUSING DOORS TO GO INTO NUDGING]

Items must be corrected by: 06/02/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CHAD MORRIS
371 NORTH BILHEN STREET
TROY, NC, 27371