



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17130-48-0682
State Number
21072

EQUIPMENT INSPECTED

State Number: 21072	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 05/23/2002	Rope Size:
Volts: 208	Complied: 05/23/2002	Entrances: 1
OWNER	OCCUPANT	
BEST HOTEL LLC	RODEWAY INN & SUITES	
4646 EAST COAST LANE NW	4646 EAST COAST LANE NW	
SHALOTTE, NC, 28470	SHALOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 05/10/2017	Type Inspection Condemned	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A ELEVATOR SHUT DOWN DUE TO HEAVY DAMAGE TO TRAVELING CABLE. [NEEDS TO BE CHANGED]

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEST HOTEL LLC
4646 EAST COAST LANE NW
SHALOTTE, NC, 28470