



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17135-73-5324
State Number
8141

EQUIPMENT INSPECTED

State Number: 8141	Type of Unit: Passenger	Floor to Floor: L to 3
Capacity: 2500	Manuf: SOUTHERN	Speed: 100
Landings: 4	Installed: 09/15/1975	Rope Size:
Volts: 220	Complied: 09/15/1975	Entrances: 1

OWNER

ALAMANCE CO OFFICE BLDG
124 W ELM ST
GRAHAM, NC, 27253

OCCUPANT

ALAMANCE CO OFFICE BLDG
124 W ELM ST
GRAHAM, NC, 27258

INSPECTION INFORMATION

Inspection Date 05/15/2017	Type Inspection Alteration	Certificate Status Issued	Inspector 73 - James	County ALAMANCE
-------------------------------	-------------------------------	------------------------------	-------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Otis

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO OFFICE BLDG
124 W ELM ST
GRAHAM, NC, 27253