



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17136-75-4612
State Number
2710

EQUIPMENT INSPECTED

State Number: 2710	Type of Unit: Freight	Floor to Floor: G to 4
Capacity: 5000	Manuf: MONARCH	Speed: 75
Landings: 5	Installed: 06/26/1956	Rope Size: 5/8
Volts: 208	Complied: 06/26/1956	Entrances: 2
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COLL	ASHEVILLE BUNCOMBE TECH COMM COLLEGE	
340 VICTORIA RD	1459 SANDHILL RD.	
ASHEVILLE, NC, 28801	CANDLER, NC, 28715	

INSPECTION INFORMATION

Inspection Date 05/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

8.6.4.13.1[a]	Properly maintain hoist way door interlocks or mechanical locks and electric contacts
2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 05/26/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dennis Messer / 828-273-2140

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801