



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17136-75-5310
State Number
H1777

EQUIPMENT INSPECTED

State Number: H1777	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: AEC	Speed: 12
Landings: 2	Installed: 08/31/2006	Rope Size: 0
Volts: 115	Complied:	Entrances: 2
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COL	HAYNES SMALL BUSINESS CENTER	
1459 SAND HILL ROAD	1459 SAND HILL ROAD	
CANDLER, NC, 28715	CANDLER, NC, 28715	

INSPECTION INFORMATION

Inspection Date 05/16/2017	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------------	----------------------------------	---------------------------	--------------------	------

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: dennis Messer / 828-273-2140

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COL
1459 SAND HILL ROAD
CANDLER, NC, 28715