



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**17136-75-5721**  
State Number  
**24208**

EQUIPMENT INSPECTED

State Number: <b>24208</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: AEC	Speed: 100
Landings: 2	Installed: 08/31/2006	Rope Size: 0
Volts: 575	Complied: 08/31/2006	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COL	HAYNES SMALL BUSINESS CENTER	
1459 SAND HILL ROAD	1459 SAND HILL ROAD	
CANDLER, NC, 28715	CANDLER, NC, 28715	

INSPECTION INFORMATION

Inspection Date 05/16/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 75 - Edwards	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 06/15/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dennis Messer / 828-273-2140

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COL  
1459 SAND HILL ROAD  
CANDLER, NC, 28715