



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17152-48-4965
State Number
H1321

EQUIPMENT INSPECTED

State Number: H1321	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: THYSSEN KRUPP	Speed: 15
Landings: 2	Installed: 10/04/2002	Rope Size: 0
Volts: 115	Complied: 10/04/2002	Entrances: 2
OWNER	OCCUPANT	
WINDSOR UNITED METHODIST CHURCH	WINDSOR METHODIST CHURCH	
% MARTHA CULBREATH	12880 NC HWY 242	
FAYETTEVILLE, NC, 28312	AMMON, NC, 28441	

INSPECTION INFORMATION

Inspection Date 06/01/2017	Type Inspection Removed	Certificate Status Not Issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	----------------------------------	--------------------------	------------------

9

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WINDSOR UNITED METHODIST CHURCH
% MARTHA CULBREATH
FAYETTEVILLE, NC, 28312