



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17153-48-1138
State Number
26232

EQUIPMENT INSPECTED

State Number: 26232	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 135
Landings: 2	Installed: 01/28/2009	Rope Size:
Volts: 200	Complied: 01/28/2009	Entrances: 1
OWNER	OCCUPANT	
OAK ISLAND TOWN HALL	SOUTH HARBOR VILLAGE FIRE DEPARTMENT	
4601 E. OAK ISLAND DR.	4151 VANESSA DRIVE	
OAK ISLAND, NC, 28465	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 06/02/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OAK ISLAND TOWN HALL
4601 E. OAK ISLAND DR.
OAK ISLAND, NC, 28465