



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17153-48-2390
State Number
24779

EQUIPMENT INSPECTED

State Number: 24779	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 05/17/2007	Rope Size: 0
Volts: 208	Complied: 05/17/2007	Entrances: 1

OWNER

SOUTH HARBOUR STATION
305 NORTH HOWE STREET
SOUTHPORT, NC, NC, 28461

OCCUPANT

SOUTH HARBOR
4134 VANESSA DR.
OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date 06/02/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTH HARBOUR STATION
305 NORTH HOWE STREET
SOUTHPORT, NC, NC, 28461