N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17156-7-4753
State Number
H2353

EQUIPMENT INSPECTED

State Number: **H2353**
Capacity: 750
Landings: 2
Volts: 230

Type of Unit: Hand Lift
Manuf: GARAVENTA
Installed: 04/17/2012
Complied:

Floor to Floor: 1 to 2
Speed: 30
Rope Size:
Entrances: 2

OWNER
BANNER ELK VISTA PROPERTIES
PO BOX 2486
BANNER ELK, NC, 28604

OCCUPANT
THE VISTAS
317 PENNY LANE
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/05/2017	Routine	Re-issued	7 - Hoffman	AVERY

6

VIOLATIONS

10.3.1.1 PERFORM THE ANNUAL TEST

Items must be corrected by: 08/04/2017

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JP 828-964-2458

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BANNER ELK VISTA PROPERTIES
PO BOX 2486
BANNER ELK, NC, 28604