



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17159-48-2798
State Number
26543

EQUIPMENT INSPECTED

State Number: 26543	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 4	Installed: 03/12/2009	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
WINGATE BY WYNDHAM	SOUTHPORT WINGATE INN	
1511 N HOWE STREET	1511 N HOWE STREET	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 06/08/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CRYSTAL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WINGATE BY WYNDHAM
1511 N HOWE STREET
SOUTHPORT, NC, 28461