



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17164-73-3754
State Number
6260

EQUIPMENT INSPECTED

| | | |
|---------------------------|-------------------------|------------------------|
| State Number: 6260 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2000 | Manuf: SOUTHERN | Speed: 75 |
| Landings: 2 | Installed: 01/13/1969 | Rope Size: |
| Volts: 220 | Complied: 05/07/1996 | Entrances: 1 |

OWNER
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215

OCCUPANT
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 06/13/2017 | Type Inspection Routine | Certificate Status Re-issued | Inspector 73 - James | County ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

1

VIOLATIONS

8.6 Clean oil from pan under pumping unit

Items must be corrected by: 08/12/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215