



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
17164-73-5539
State Number
9956

EQUIPMENT INSPECTED

State Number: 9956	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: SOUTHERN	Speed: 75
Landings: 2	Installed: 09/02/1981	Rope Size:
Volts: 220	Complied: 09/02/1981	Entrances: 1

OWNER
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215

OCCUPANT
CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 06/13/2017	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

2.14.7.1.2	Place the passenger cab interior lights in working order. 50 lx or 5 fc @ the cab floor.
8.6	Tighten loose handrails in car

Items must be corrected by: 08/12/2017

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAROLINA BIO SUPPLY
2700 YORK RD
BURLINGTON, NC, 27215